



MUNICIPALITY OF BLUEWATER
RFP: BW-Fire-02-2026

To Supply and Deliver: Thirty two (32) Current NFPA Edition 4500 psi Self Contained Breathing Apparatus, Sixty four (64) 4500 psi composite bottle, sixty four (64) face pieces, Four (4) Rapid intervention Kits and Management Software

ADDENDUM NO. 1
September 24, 2026

Bidders shall note the following:

Annex A – SCBA – General Requirements

TR #3: should read as follows:

“System pressure shall be 4,500 PSIG with low-profile carbon fibre cylinders, rated for a forty-five (45) minute duration. The back frame shall be capable of securing 30-, 45-, and 60-minute cylinders without modification. Cylinder manufacture dates shall be within three (3) months of delivery.”

TR#25: should read as follows:

“Voice Amplifier Speaker Module available for each Face-piece or SCBA pack, projecting the user’s voice in the direction the user is facing. Preference will be given to modular amplifiers that are field - upgradeable to radio interface (RI) and radio direct interface (RDI) functionality without affecting NFPA certification.”